

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Independent LED driver

Name and address of the applicant

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, 24891 New Taipei City, Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, 24891 New Taipei City, Taiwan

Name and address of the factory

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, 510890 Guangzhou Guangdong, China*When more than one factory* [Additional information on page 2](#)

Ratings and principal characteristics

Product dataRatings: Input: 100-240 Vac, 5,5 A, 50/60 Hz, IP65, IP67 or IP68, tc: 90 °C, ta: 50 °C for 200-240 V, ta: 40 °C for 100-200 V, PF: 0,95, independent SELV, Class I, constant voltage mode.
Other information refers to General product information of test report.

Trademark / Brand (if any)



MEAN WELL

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HLG-480H-xy and HLGP-480H-xy

Additional information

 [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016

National differences:

AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

4922070.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-06-16

Signature: R Zhou



Ref. Certif. No.

NL-108244

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

YONGDEN TECHNOLOGY CORPORATION
345 MacArthur HighWay Tabang, 3015 Guiguinto, Bulacan, Philippines

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, 24891 New Taipei City, Taiwan

SuZhou MEAN WELL Technology Co., Ltd.
No.269, Changping Road, Huangdai Town, Xiangcheng District, 215152 Suzhou Jiangsu, China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, 560058 Bengaluru (BANGALORE) Urban,
Karnataka, India

Additional information

Model/Type reference:

HLG-480H-xy, HLGP-480H-xy

The "x" can be 24, 30, 36, 42, 48 or 54 to denote the output voltage (unit is Vdc).

"y" can be Blank, A, B, AB, Dx or D2 to denote the optional function for HLG-480H-xy series.

"y" can be Blank, A, B or AB to denote the optional function for HLGP-480H-xy series

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2024-06-16

Signature: R Zhou